



*Carlisle Brass Ltd
Parkhouse Road
Carlisle
Cumbria
CA3 0JU*

Tel: 01228 211770

EC - DECLARATION OF CONFORMITY

Number CB207

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulations or CPR), we declare that the construction product

Range of Eurospec Mortice Latches – see Annex A

Placed on the market

**Carlisle Brass Ltd
Parkhouse Road, Carlisle, Cumbria, CA3 0JU**

Complies with all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 12209:2003/AC 2005

with classification

See Annex A

on the basis that the approved body

Element Materials Technology Rotterdam B.V. – (EC Notified Body 2812)

has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control as shown in the Certificate of Conformity Ref. 2812-CPR-AG0156, dated 23rd December 2020.

Intended use: For use on fire / smoke compartmentation doors

Essential characteristic	Performance	Harmonised technical specification
Self-closing 5.4.2 Closing force 5.1.2 Re-latching force of latch bolt	Grade 7 = 100kg door mass with 15N maximum closing force >2.5N	EN 12209:2003/AC2005
Durability of self-closing 5.3.1 Durability of latch action	Grade A = 50,000 cycles with no side load on latch bolt	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1	
Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Paul Campbell



Technical Manager

12th January 2021

Annex A

Lock Reference	Description	EN12209:2003 Classification Achieved										
		*	A	7	1	0	*	-	B	0	*	0
TLS5025	Easi-T Heavy Sprung Tubular Latch 2.5"	*	A	7	1	0	*	-	B	0	*	0
TLS5030	Easi-T Heavy Sprung Tubular Latch 3"	*	A	7	1	0	*	-	B	0	*	0
TLS5040	Easi-T Heavy Sprung Tubular Latch 4"	*	A	7	1	0	*	-	B	0	*	0
TLS5050	Easi-T Heavy Sprung Tubular Latch 5"	*	A	7	1	0	*	-	B	0	*	0
FLL8025	Original Flat Latch 2.5"	*	A	7	1	0	*	-	*	0	*	0
FLL8030	Original Flat Latch 3"	*	A	7	1	0	*	-	*	0	*	0
FLL8040	Original Flat Latch 4"	*	A	7	1	0	*	-	*	0	*	0

*NPD (no performance determined)