


## Pushbar Panic Latch

**XDL5760SV**



- BS EN 1125:2008 (3-7-6-B-1-4-2-2-A-A)
- CE Marked (2812-CPR-AAA010)
- UKCA Marked (1121-CPR-UK-AAA7781)
- Certifire Approved (CF719)
- Timber Door Fire (Without ELA) 20-120 Minutes
- Timber Door Fire (With ELA) 20-30 Minutes
- Steel Door fire (Without ELA) 120 Minutes
- With XSA5003 ELA 90 Minutes / With XIA5003 ELA 120 Minutes

